



FIRE REGULATION SYMBOLS	
	Exit Boxes
	Escape Lighting Points
	Fire Extinguisher Water
	Fire Extinguisher CO ²
	Auto Smoke detector
	Push bar Emerg. exit
	Fire Alarm Call Points
	Audible Warning Device
	Fire blanket
	Hand Operated Personell Attack Alarm Button
	Control Panel
	CCTV Camera
	Extent of licenced area

An electrically operated fire alarm system should comply with B55839, Part 1:2002. The electrical installation should comply with approved Document P (electrical safety). It is essential that the fire detection and fire alarm systems are properly designed, installed and maintained. Where a fire alarm system is installed, an installation and commissioning certificate should be provided.

The smoke and heat alarm system is to be mains-operated and conform to B55446, 1:2000 or B55446, respectively: fire detection and fire alarm devices for dwellings, Part 1 specification for smoke alarms; or Part 2 specification for heat alarms

The emergency lighting installation is to comply with B55266, Part 1, 2002 and the attention of the design/installing engineer drawn to paragraph 3.1 (construction and records) of B55266, Part 1, 1988, which requires consultation with the Fire Authority. Firefighting equipment is to conform with BS EN3.

Fire Safety related signs and notices are to conform to B55499, Part 1, 1990 (incorporating 'running man' symbol on fire exits) and other pictograms as required. Illuminated 'EXIT' signs are to conform to B52560.

Liquor Store to be sealed and the door to be half hour fire resistant in accordance with BS476, 1972 as amended.

Drawing Purpose	PREMISES LICENCE APPLICATION
Drawing Details	The purpose of this drawing is for the submission of a Premises Licence Application. All Measurements have been drawn in millimeters. This drawing is not be used for the intention of any building, shop fitting or construction purposes.

Name of Premises	Groszek European Market
------------------	--------------------------------

Premises Address	36 Lowesmoor, Worcester, WR1 2SG
------------------	---

SCALE	1 : 100 @ A3
-------	---------------------